



November 13, 1998

Mr. David O'Dell  
Greene County Building Regulations  
940 Boonville  
Springfield, MO 65802

RE: Sanitary Sewer Review  
CTI Trucking, Inc. (New Facility)  
4800 Block W. Maple

Dear Mr. O'Dell:

Enclosed is the review copy of the Building Plans with comments enclosed. The following comments were made by Mr. Bob Schaefer.

Not Approved.

- a. Private sewer lateral across other property to the east is not allowed.
- b. Must design a public sanitary sewer extension from Miller Avenue to this property and submit plans to Springfield Public Works Department for approval.
- c. Must build public sanitary sewer extension after plans are approved and pay inspection fee for City construction inspection of the public line.
- d. After public sewer is completed must pay sewer impact fee prior to connection.
- e. Storage Room on sheet P077.20, needs dike around so spillage or leakage cannot enter the floor drain.
- f. Need an additional sheet P077.31.

Carl W. Knuckles, P.E.  
Professional Engineer

cc: Bob Schaefer  
Ed Malter  
King Coltrin  
Randy Lyman

4700 BLOCK W. MAPLE